

MECHANICAL GENERAL NOTES

- 1. ALL WORK SHALL COMPLY WITH THE 2018 EDITION OF THE "ARKANSAS MECHANICAL CODE", THE 2014 EDITION OF THE "ARKANSAS ENERGY CODE", NFPA 90A, AND ALL CITY, STATE, AND LOCAL REQUIREMENTS.
- 2. CONTRACT DOCUMENTS INCLUDE BOTH PLANS AND THE PROJECT MANUAL/SPECIFICATIONS. REFER TO THE PROJECT MANUAL/SPECIFICATIONS FOR ALL REQUIREMENTS NOT INDICATED ON THE PLANS AND VICE-VERSA. WHERE CONFLICTS EXIST, THE MOST STRINGENT SHALL TAKE PRECEDENCE
- 3. REFER TO ARCHITECTURAL PLANS FOR:
- A. REFLECTED CEILING PLAN FOR EXACT LOCATION OF AIR DEVICES AND CEILING TYPES.
- B. FIRE-RATED WALLS AND PARTITIONS. PROVIDE FIRE DAMPERS IN DUCT PENETRATIONS OF ALL FIRE RATED WALLS AND PARTITIONS AS
- NECESSARY TO MEET CITY AND STATE REQUIREMENTS.
- C. ALL WALL AND ROOF PENETRATIONS AND EQUIPMENT MOUNTING DETAILS.
 4. DUCTWORK SHALL BE CONSTRUCTED FROM GALVANIZED STEEL IN CONFORMANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS,"
- 5. U.L. LISTED FLEXIBLE DUCT RUN-OUTS MAY BE USED BUT SHALL NOT EXCEED 5'-0" IN LENGTH. ALL FLEXIBLE DUCT TO BE PROPERLY SUPPORTED WITH NO KINKS OR HARD BENDS.
- 6. DUCT FITTINGS:
- . DUCT FITHINGS.

 A CUIDDLY TAKE OFFO TO OFFILIAD CUIDDLY DIFFLIOFDO TO DE CONJOAL TAD OD 45° CIDE TAI
- A. SUPPLY TAKE-OFFS TO CEILING SUPPLY DIFFUSERS TO BE CONICAL TAP OR 45° SIDE TAP.B. ALL DUCT RUN-OUTS SHALL HAVE LOCKING QUADRANT VOLUME DAMPERS. PROVIDE STAND-OFF BRACKET TO ACCOMMODATE INSULATION
- THICKNESS. ALL 90° ROUND ELBOWS TO HAVE R/D=1.5 (UNLESS OTHERWISE NOTED).
- C. ALL RECTANGULAR MITERED ELBOWS 45° OR GREATER SHALL HAVE TURNING VANES (UNLESS OTHERWISE NOTED).D. PROVIDE HARD ELBOW WHEN TRANSITIONING FROM RIGID TO FLEXIBLE DUCT WHEN CONNECTING TO AIR DEVICES. REFER TO DETAIL.
- 7. DUCTWORK TO BE COORDINATED WITH STRUCTURAL, ELECTRICAL, PLUMBING, AND FIRE PROTECTION, COMPONENTS AND SYSTEMS. ALL DUCTWORK THAT HAS TO BE OFFSET DUE TO AN OBSTRUCTION SHALL BE SLOPED WITH 2-30° ELBOWS UNLESS OTHERWISE NOTED.
- 8. COMPLETELY INSULATE THE TOPS OF ALL CEILING DIFFUSERS.
- 9. CLOSELY COORDINATE LOCATIONS OF INSTALLED EQUIPMENT TO ACHIEVE THE GREATEST ACCESSIBILITY.
- 10. MAINTAIN 10'-0" MINIMUM CLEARANCE BETWEEN OUTSIDE AIR INTAKES AND ALL EXHAUST FANS, FLUES, PLUMBING VENTS, ETC.
- 11. PROVIDE FLEXIBLE CONNECTIONS AT INLETS AND OUTLETS OF ALL AIR HANDLING UNITS, MAKE-UP AIR UNITS, FURNACES, AND/OR EXHAUST FANS.
 12. RPROVIDE 6" CONCRETE PADS UNDER ALL GROUND MOUNTED PACKAGED HVAC UNITS. EACH PAD TO EXTEND A MINIMUM OF 6" BEYOND OUTLINE
- OF UNIT ON ALL SIDES.

 13. CONDENSATE PIPING SHALL BE COMPRISED OF TYPE "M", DWV COPPER, OR SCHEDULE 40 PVC. PVC EXPOSED TO SUNLIGHT SHALL HAVE UV RESISTANT COATING.
- 14. COORDINATE WORK CLOSELY WITH CONTROL CONTRACTOR. PROVIDE ALL NECESSARY DUCT, PIPE TAPS, TEES, WELLS, CONTROL DAMPERS, AIR MEASURING STATIONS, AND OTHER ACCESSORIES REQUIRED BY CONTROL SYSTEM
- 15. SLEEVE AND SEAL ALL PIPE AND DUCT PENETRATIONS THROUGH FIRE RATED AND NON-RATED SLABS AND PARTITIONS.

MECHANICAL DEMOLITION GENERAL NOTES

- 1. CONTRACTOR SHALL VERIFY EXISTING SITE CONDITIONS INCLUDING, BUT NOT LIMITED TO:
- A. PIPE AND DUCT SIZES AND ROUTING.
- B. AIR DEVICE TYPE AND LOCATIONS.
- C. EQUIPMENT CONNECTIONS AND LOCATIONS.
- D. CONTROLS
- 2. PROVIDE NECESSARY MODIFICATIONS TO NEW AND EXISTING SYSTEMS TO FACILITATE THE INSTALLATION AND INTERFACE OF NEW AND EXISTING SYSTEMS.
- 3. EXISTING SYSTEMS AND INFORMATION SHOWN ON THESE PLANS WERE DEVELOPED USING NON-DESTRUCTIVE SITE OBSERVATIONS.

 CONTRACTOR SHALL FIELD VERIFY AT SITE ALL EXISTING SYSTEMS AND CONDITIONS PRIOR TO BID. THE CONTRACTOR SHALL MAKE
 ADJUSTMENTS AS NEEDED TO SUIT ACTUAL EXISTING SITE CONDITIONS AS REQUIRED TO ENSURE A COMPLETE, OPERABLE, AND WARRANTABLE INSTALLATION OF THE SCOPE OF WORK OF THIS PROJECT.
- 4. REMOVE AND RELOCATE SMALL CONDUIT, CABLE, PIPE AND DUCT, PIPE AND CEILING HANGERS ETC. AS NECESSARY TO ACHIEVE A COMPLETE
- INSTALLED MECHANICAL SYSTEM AS SHOWN ON DRAWINGS.
 5. PATCH ALL WALLS, FLOORS, ROOFS AND CEILINGS TO MATCH EXISTING OR NEW (IF APPLIED) FOR ALL OPENINGS CREATED BY DEMOLITION WORK OF EQUIPMENT AND HVAC SERVICE PENETRATIONS.
- 6. REPLACE AND/OR PATCH TO MATCH EXISTING ANY EXISTING PIPE AND/OR DUCT INSULATION THAT IS TO REMAIN EXISTING AND IS DAMAGED OR REMOVED DURING CONSTRUCTION.



1300 East 6th Street Little Rock, AR 72202 501.372.2900 cromwell.com

Proiect

3

Design Phase

AST CAMDEN,

CONSTRUCTION DOCUMENTS

Revisions —		
		Description

Stamp





. . .

CROMWELL ARCHITECTS ENGINEERS, INC.
 ALL RIGHTS RESERVED

2. THIS SHEET DESIGNED FOR COLOR PRINTING.
CRITICAL INFORMATION MAY BE LOST WITH
BLACK AND WHITE PRINTING.

Project Number

MECHANICAL LEGEND

AND SYMBOLS

2024-134

12-19-2024

Sheet Number

M-001