

**SECTION 06 10 00**  
**ROUGH CARPENTRY**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Nonstructural dimension lumber framing.
- B. Sheathing.
- C. Preservative treated wood materials.
- D. Concealed wood blocking, nailers, and supports.
- E. Miscellaneous wood nailers, furring, and grounds.

**1.02 REFERENCE STANDARDS**

- A. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2016a.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2020.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2021a.
- D. AWPA U1 - Use Category System: User Specification for Treated Wood; 2018.
- E. PS 20 - American Softwood Lumber Standard; 2020.
- F. SPIB (GR) - Grading Rules; 2014.

**1.03 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide technical data on wood preservative materials and application instructions.

**1.04 DELIVERY, STORAGE, AND HANDLING**

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.

**PART 2 PRODUCTS**

**2.01 GENERAL REQUIREMENTS**

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
  - 1. If no species is specified, provide species graded by the agency specified; if no grading agency is specified, provide lumber graded by grading agency meeting the specified requirements.
  - 2. Grading Agency: Grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee at [www.alsc.org](http://www.alsc.org), and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.

**2.02 DIMENSION LUMBER FOR CONCEALED APPLICATIONS**

- A. Grading Agency: Southern Pine Inspection Bureau, Inc; SPIB (GR).
- B. Sizes: Nominal sizes as indicated on drawings, S4S.
- C. Moisture Content: S-dry or MC19.
- D. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring:
  - 1. Lumber: S4S, No. 2 or Standard Grade.
  - 2. Boards: Standard or No. 3.

## **2.03 CONSTRUCTION PANELS**

- A. Exterior Wall Sheathing: Plywood, PS 1, Grade C-D, Exposure I, exterior type.

## **2.04 ACCESSORIES**

- A. Fasteners and Anchors:
  - 1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for high humidity and preservative-treated wood locations, unfinished steel elsewhere.

## **2.05 FACTORY WOOD TREATMENT**

- A. Treated Lumber and Plywood: Comply with requirements of AWWPA U1 - Use Category System for wood treatments determined by use categories, expected service conditions, and specific applications.
  - 1. Preservative-Treated Wood: Provide lumber and plywood marked or stamped by an ALSC-accredited testing agency, certifying level and type of treatment in accordance with AWWPA standards.
- B. Preservative Treatment:
  - 1. Products:
    - a. Arch Wood Protection, Inc: [www.wolmanizedwood.com](http://www.wolmanizedwood.com).
    - b. Koppers Performance Chemicals, Inc: [www.koppersperformancechemicals.com](http://www.koppersperformancechemicals.com).
    - c. Viance, LLC: [www.treatedwood.com](http://www.treatedwood.com).
    - d. Substitutions: See Section 01 60 00 - Product Requirements.
  - 2. Preservative Pressure Treatment of Lumber Above Grade: AWWPA U1, Use Category UC3B, Commodity Specification A using waterborne preservative.
    - a. Kiln dry lumber after treatment to maximum moisture content of 19 percent.

## **PART 3 EXECUTION**

### **3.01 PREPARATION**

- A. Coordinate installation of rough carpentry members specified in other sections.

### **3.02 INSTALLATION - GENERAL**

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.
- C. Where treated wood is used on interior, provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

### **3.03 BLOCKING, NAILERS, AND SUPPORTS**

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly indicated.
- C. Where ceiling-mounting is indicated, provide blocking and supplementary supports above ceiling, unless other method of support is explicitly indicated.
- D. Provide the following specific nonstructural framing and blocking:
  - 1. Wall brackets.

### **3.04 INSTALLATION OF CONSTRUCTION PANELS**

- A. Wall Sheathing: Secure with long dimension perpendicular to wall studs, with ends over firm bearing and staggered, using nails, screws, or staples.

### **3.05 TOLERANCES**

- A. Framing Members: 1/4 inch (6 mm) from true position, maximum.

- B. Variation from Plane, Other than Floors: 1/4 inch in 10 feet (2 mm/m) maximum, and 1/4 inch in 30 feet (7 mm in 10 m) maximum.

### **3.06 CLEANING**

- A. Waste Disposal: See Section 01 74 19 - Construction Waste Management and Disposal.
- B. Comply with applicable regulations.
- C. Do not burn scrap on project site.
- D. Do not burn scraps that have been pressure treated.
- E. Do not send materials treated with pentachlorophenol, CCA, or ACA to co-generation facilities or "waste-to-energy" facilities.
- F. Do not leave wood, shavings, sawdust, etc. on the ground or buried in fill.
- G. Prevent sawdust and wood shavings from entering the storm drainage system.

**END OF SECTION**

**This page was intentionally left blank for duplex printing.**