# SECTION 10 44 00 FIRE PROTECTION SPECIALTIES

## **PART 1 GENERAL**

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

## 1.02 SECTION INCLUDES

- A. Fire extinguishers.
- B. Fire extinguisher cabinets.
- C. Fire department building rapid entry system.
- D. Accessories.

## 1.03 RELATED REQUIREMENTS

- A. Section 06 10 00 Rough Carpentry: Wood blocking product and execution requirements.
- B. Section 09 91 23 Interior Painting: Field paint finish.

## 1.04 REFERENCE STANDARDS

- ASTM E814 Standard Test Method for Fire Tests of Penetration Firestop Systems; 2023a.
- B. FM (AG) FM Approval Guide; Current Edition.
- C. NFPA 10 Standard for Portable Fire Extinguishers; 2022.
- D. UL (DIR) Online Certifications Directory; Current Edition.

## 1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide extinguisher ratings and classifications, color and finish, and anchorage details.
- C. Shop Drawings: Indicate locations of cabinets and cabinet physical dimensions.
- D. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

## 1.06 FIELD CONDITIONS

A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

### PART 2 PRODUCTS

## 2.01 MANUFACTURERS

- A. Fire Extinguishers:
  - Amerex: www.amerex-fire.com.
  - 2. Kidde, a unit of United Technologies Corp: www.kidde.com.
  - 3. JL Industries, Inc: www.jlindustries.com.
  - 4. Oval Brand Fire Products; Oval Dry Chemical Fire Extinguisher Multipurpose ABC: www.ovalfireproducts.com/#sle.
  - 5. Potter Roemer; potterroemer.com
  - Strike First Corporation of America; ABC-Seamless Steel Fire Extinguisher: www.strikefirstusa.com.
  - 7. Substitutions: See Section 01 60 00 Product Requirements.
- B. Fire Extinguisher Cabinets and Accessories:

- 1. Activar Construction Products Group, Inc. JL Industries; Ambassador Series: www.activarcpg.com/#sle.
- 2. Larsen's Manufacturing Co: www.larsensmfg.com/#sle.
- 3. Oval Brand Fire Products; Cabinets for Low Profile Extinguishers: www.ovalfireproducts.com/#sle.
- 4. Potter-Roemer: www.potterroemer.com/#sle.
- 5. Strike First Corporation of America; EL-Elite Architectural Series Fire Extinguisher Cabinet, Non-Fire Rated: www.strikefirstusa.com.
- 6. Substitutions: See Section 01 60 00 Product Requirements.

### 2.02 FIRE EXTINGUISHERS

- Fire Extinguishers General: Comply with product requirements of NFPA 10 and applicable codes, whichever is more stringent.
  - Provide extinguishers labeled by UL (DIR) or FM (AG) for purpose specified and as indicated.
  - 2. Provide Bi-lingual labels.
- B. Multipurpose Dry Chemical Type Fire Extinguishers: Carbon steel tank, with pressure gauge.
  - 1. UL-rated 4-A:80-B:C, 10-lb nominal capacity.
  - 2. Size: 10 pound (4.54 kg) capacity.
  - 3. Finish: Baked polyester powder coat, color as selected.
  - 4. Temperature range: Minus 40 degrees F (Minus 40 degrees C) to 120 degrees F (49 degrees C).

## 2.03 FIRE EXTINGUISHER CABINETS

- A. Fire Rating: Listed and labeled in accordance with ASTM E814 requirements for fire resistance rating of walls where being installed.
- B. Cabinet Construction: Non-fire rated.
  - 1. Formed primed steel sheet; 0.036 inch (0.9 mm) thick base metal.
- C. Fire Rated Cabinet Construction: One-hour fire rated.
- D. Provide fire rated cabinets where installed in fire rated partitions.
- E. Cabinet Configuration: Semi-recessed type.
  - Size to accommodate accessories.
    Exterior nominal dimensions of 12 inch (\_\_\_\_ mm) wide by 27 inch (\_\_\_\_ mm) high by 4 inch (\_\_\_\_ mm) deep.
  - 3. Trim: Flat square edge, with 1 1/2 inch ( mm) wide face.
- F. Door: 0.036 inch (0.9 mm) thick, reinforced for flatness and rigidity; recessed latch, unless otherwise indicated. Hinge doors for 180 degree opening with continuous piano hinge. Provide roller type catch.
- G. Door Glazing: Tempered glass, clear, 1/8 inch (3 mm) thick, and set in resilient channel glazing gasket.
  - 1. Vertical Duo type with glazing.
- Cabinet Mounting Hardware: Appropriate to cabinet, with pre-drilled holes for placement of anchors.
- I. Fabrication: Weld, fill, and grind components smooth.
- J. Finish of Cabinet Exterior Trim and Door: Baked enamel or powder coated, color as selected.
- K. Finish of Cabinet Interior: Match exterior.

## 2.04 FIRE DEPARTMENT RAPID ENTRY SYSTEM

- A. Provide a recessed rapid access entry key box acceptable to the Authorities Having Jurisdiction. KnoxBox 3200, or equal.
- B. Provide optional tamper switch connection for Fire Alarm

- C. Submit color options for selection by AE.
- D. Locate as indicated, or if not indicated as directed by Architect and acceptable to the Authorities Having Jurisdiction.

### 2.05 ACCESSORIES

- A. Extinguisher Brackets: Formed steel, galvanized and enamel finished.
- B. Extinguisher Theft Alarm: Battery operated alarm, minimum 10 second delay for disarming, activated by opening cabinet door.
- C. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location. Locate as indicated by Architect.
- D. Wall Signage: Provide for each fire extinguisher or cabinet.Locate as directed.
  - 1. Key Features
    - a. Acrylic
    - b. Triangular
    - c. Measures 8.5 inch wide, 3.25 inch deep, 18 inch high
  - 2. Similar to: Brady "Tall Fire Extinguisher "V" Sign" Part Number SP818V
- E. Cabinet Signage: Die-cut vinyl, 3/4 inch by 18 inch, vertical, red, "FIRE EXTINGUISHER".

### PART 3 EXECUTION

## 3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Coordinate size of cabinets to ensure that the type and capacity of appliances and accessories indicated are accommodated.
- C. Coordinate sizes and locations of fire protection cabinets with wall depths.
- D. Verify rough openings for cabinet are correctly sized and located.
- E. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install cabinets plumb and level in wall openings, 24 inches (\_\_\_\_ mm) from finished floor to inside bottom of cabinet. Mounting height as required by Authorities Having Jurisdiction for ADA Accessibility Guidelines from finished floor to the carrying handle.
- C. Secure rigidly in place.
- D. Place extinguishers in cabinets, unless otherwise indicated.
- E. Position cabinet signage at wall, directly above cabinet and lettering on cabnet doors after painting is complete..
- F. Remove temporary protective coverings and strippable films, if any, as fire-protection cabinets are installed unless otherwise indicated in manufacturer's written installation instructions.
- G. Adjust fire-protection cabinet doors to operate easily without binding. Verify that integral locking devices operate properly.
- H. On completion of fire-protection cabinet installation, clean interior and exterior surfaces as recommended by manufacturer.
- I. Touch up marred finishes, or replace fire-protection cabinets that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by fire-protection cabinet and mounting bracket manufacturers.
- J. Replace fire-protection cabinets that have been damaged or have deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

### **END OF SECTION**

Aerojet Rocketdyne Building E33 Office Expansion East Camden, Arkansas