

SECTION 23 34 23
HVAC POWER VENTILATORS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SECTION INCLUDES

- A. Ceiling exhaust fans.

1.03 RELATED REQUIREMENTS

- A. Section 23 05 13 - Common Motor Requirements for HVAC Equipment.
- B. Section 23 05 48 - Vibration And Seismic Controls For HVAC Piping And Equipment.
- C. Section 23 33 00 - Air Duct Accessories: Backdraft dampers.
- D. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections.
- E. Section 26 27 26 - Wiring Devices: Electrical characteristics and wiring connections.

1.04 REFERENCE STANDARDS

- A. AMCA (DIR) - (Directory of) Products Licensed Under AMCA International Certified Ratings Program; 2015.
- B. AMCA 99 - Standards Handbook; 2016.
- C. AMCA 204 - Balance Quality and Vibration Levels for Fans; 2020.
- D. AMCA 210 - Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating; 2016, with Errata (2018).
- E. AMCA 300 - Reverberation Room Methods of Sound Testing of Fans; 2024.
- F. AMCA 301 - Methods for Calculating Fan Sound Ratings from Laboratory Test Data; 2022.
- G. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- H. UL 705 - Power Ventilators; Current Edition, Including All Revisions.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on fans and accessories including fan curves with specified operating point clearly plotted, power, RPM, sound power levels at rated capacity, and electrical characteristics and connection requirements.
- C. Manufacturer's Instructions: Indicate installation instructions.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.

1.07 FIELD CONDITIONS

- A. Permanent ventilators may not be used for ventilation during construction.

PART 2 PRODUCTS

2.01 POWER VENTILATORS - GENERAL

- A. Static and Dynamically Balanced: AMCA 204 - Balance Quality and Vibration Levels for Fans.
- B. Performance Ratings: Determined in accordance with AMCA 210 and bearing the AMCA Certified Rating Seal.
- C. Sound Ratings: AMCA 301, tested to AMCA 300 and bearing AMCA Certified Sound Rating Seal.

- D. Fabrication: Comply with AMCA 99.
- E. UL Compliance: UL listed and labeled, designed, manufactured, and tested in accordance with UL 705.
- F. Electrical Components: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.
- G. Enclosed Safety Switches: Comply with NEMA 250.

2.02 CEILING EXHAUST FANS

- A. Centrifugal Fan Unit: V-belt or direct driven with galvanized steel housing lined with acoustic insulation, resiliently mounted motor, gravity backdraft damper in discharge.
- B. Disconnect Switch: Cord and plug in housing for thermal overload protected motor and wall mounted solid state speed controller.
- C. Grille: Molded white plastic.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Provide sheaves required for final air balance.
- C. Install backdraft dampers on inlet to roof-mounted and externally-mounted wall exhausters.
- D. Provide backdraft dampers on outlet from cabinet and ceiling exhausters fans and as indicated.
- E. Provide backdraft dampers or motorized dampers in the wall housing or wall collar of sidewall propeller fans.

END OF SECTION