





## **GENERAL NOTES**

1 REFER TO SHEET M-001 FOR MECHANICAL NOTES, ABBREVIATIONS, AND LEGEND SYMBOLS.

## KEYED NOTES

- 1 INSTALL BACKDRAFT DAMPER W/ BLADE SEAL TO ENSURE 100% SEAL.
- 2 PROVIDE 6" CONCRETE MECHANICAL PAD.
- PROVIDE EQUIPMENT ACCESS PANEL IN CEILING. PANEL TO BE INSULATED AND 3 GASKETED.
- PROVIDE INTEGRAL DAMPER OPERABLE FROM FACE OF AIR DEVICE.
- RISE WITH DUCT ALONG THE WALL, PENETRATE WALL TO BUILDING INTERIOR AT APPROXIMATELY 12'-0" A.F.F.
- RISE WITH DUCT ALONG THE WALL, PENETRATE WALL TO BUILDING INTERIOR AT APPROXIMATELY 14'-0" A.F.F.
- ROUTE EXHAUST DUCT APPROXIMATELY 9'4" A.F.F. AROUND BUILDING EXTERIOR.
- INSTALL 1x1, 30"x30", 1-FILTER UNIT, CEILING MOUNTED HEPA FILTER HOUSING EQUAL TO "CAMFIL PHARMASEAL PW-30Z30Z-15L-OB-E-BK-S-F-2011" WITH CAMFIL FILTRA 2000 HEPA FILTER FOR 99.99% FILTRATION. FILTER TO HAVE ROOM SIDE FILTER SERVICABILITY.

 $\frac{2}{2}$ 

- INSTALL 1x2, 30"x56", 2-FILTER UNIT, CEILING MOUNTED HEPA FILTER HOUSING EQUAL TO "CAMFIL PHARMASEAL PW-30Z56Z-15L-OB-E-BK-S-F-2011" WITH CAMFIL FILTRA 2000 HEPA FILTER FOR 99.99% FILTRATION. FILTER TO HAVE ROOM SIDE FILTER SERVICABILITY.
- 10 INSTALL SIDE ACCESS HEPA FILTER HOUSING IN DUCTWORK EQUAL TO "CAMFIL MAGNA/PACK M/P 4-12 PF 1x1" WITH CAMFIL 01XH ABSOLUTE HIGH CAPACITY HEPA FILTER FOR 99.99% FILTRATION. HOUSING TO BE MOUNTED ON EXTERIOR WALL IN DUCTWORK AND BE WEATHER-PROOF.
- CONNECT EXHAUST DUCTWORK TO OWNER PROVIDED EQUIPMENT. COORDINATE WITH OWNER FOR CONNECTION REQUIREMENTS.
- INSTALL NEW HOOD EXHAUST FAN. COORDINATE WITH OWNER FOR FAN CONTROLLER LOCATION AND SEQUENCES.
- ROUTE STAINLESS STEEL EXHAUST DUCTWORK TO EXTERIOR MANUFACTURER'S WALL CAP. CONTRACTOR TO COORDINATE ROUTING CONFLICTS.



