

To:	<b>Polk Stanley Wilcox Architects</b>	From:	<b>Marc White / Chris W Mann</b>
Attention:	<b>Jim Thacker</b>	Copy To:	<b>Rodney Parham</b>
Subject:	<b>English Pub Addendum 1 dated 2/25/2025</b>		

## **MEP Summary of Revisions:**

### **Mechanical Drawings:**

Refer to revised Sheet M001 (Mechanical Notes, Legend and Index) dated 2/25/2025:

1. Added note 12 to 'Control Notes'.
2. Revised Legend to add CO sensor.

Refer to revised Sheet M101 (HVAC Floor Plans) dated 2/25/2025:

1. Revised keyed notes.
2. Added section 2/M102.
3. Deleted in-duct smoke detector from RTU-3 return duct.
4. Added carbon monoxide sensors.
5. Added exhaust fan timer location.

Refer to revised Sheet M102 (HVAC Roof Plans) dated 2/25/2025:

1. Added section 2/M102.
2. Deleted in-duct smoke detector from RTU-4 return duct.

Refer to revised Sheet M301 (Mechanical Schedules) dated 2/25/2025:

1. Revised airflows and ESP on RTU schedule.
2. Changed EF-1 and 2 to upblast fans.

### **Mechanical Specifications:**

1. Deleted specification sections 230523, 230900 and 238129.
2. Revised specification sections 230553 and 230719.

### **Plumbing Drawings:**

Refer to revised Sheet P101 (Sanitary Sewer and Storm Drain Floor Plans) dated 2/25/2025:

1. Revised keyed notes.

Refer to revised Sheet P201 (Domestic Water and Natural Gas Floor Plans) dated 2/25/2025:

1. Revised keyed notes.
2. Revised gas pipe sizes.
3. Added gas piping for fire places.

Refer to revised Sheet P202 (Domestic Water and Natural Gas Roof Plan) dated 2/25/2025:

1. Added gas piping for fire places.

Refer to revised Sheet P301 (Plumbing Details) dated 2/25/2025:

1. Revised grease trap detail 19/P301.

Refer to revised Sheet P401 (Plumbing Schedules and risers) dated 2/25/2025:

1. Revised gas pipe sizes for natural gas header.

**Electrical Drawings:**

Refer to revised Sheet E201 (First Floor Lighting Plan) dated 2/25/2025:

1. Deleted (1) Type "L" bar pendant fixture.

Refer to revised Sheet E301 (First Floor Power & Systems Plan) dated 2/25/2025:

1. Clarified Kitchen Equipment Item #13 electrical requirements.
2. Added POS / KDS locations with power and data.
3. Added duct smoke detectors for RTU-1 & RTU-2.
4. Clarified Kitchen Hood electrical wiring/connection requirements.
5. Added power for fireplace.

Refer to revised Sheet E302 (Second Floor Power & Systems Plan) dated 2/25/2025:

1. Added POS / KDS locations with power and data.
2. Added power for fireplace.
3. Added power to covered patio motorized shades.

Refer to revised Sheet E501 (Electrical One-Line Diagram & Panel Schedules) dated 2/25/2025:

1. Added circuits to Panel "2PP1" for motorized shades.

**Fire Protection Drawings:**

Refer to revised Sheet F001 (Fire Protection Notes, Legend and Index) dated 2/25/2025:

1. Added Fire Protection note.