DOOR SCHEDULE - LEVEL 2

DOOR NUMBER	ROOM		DOOR							FRAME		FRAME DETAILS					
	FROM ROOM	TO ROOM	WIDTH	HEIGHT	PANEL TYPE	MATERIAL	FINISH	THICKNESS	DOOR GLAZING	FRAME TYPE	MATERIAL	HEAD	JAMB	HARDWARE SET	FIRE RATING	STC RATING	COMMENTS
LEVEL 2																	
2-101.1A	STORAGE	MACH	3' - 6"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-101A	STORAGE	ELEVATOR LOBBY	6' - 0"	7' - 0"	AA		<By Category>	1 3/4"	<By Category>	1	HM			SSI2-G-E1			
2-101B	STORAGE	ELEVATOR LOBBY	6' - 0"	7' - 0"	AA		<By Category>	1 3/4"	<By Category>	1	HM			SSI2-G-E1			
2-102A	RR CORRIDOR	MEN'S RR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-T3			
2-102B	RR CORRIDOR		3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM						
2-104.1A	CORRIDOR	ELECTRICAL	6' - 0"	7' - 0"	AA		<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 1			
2-104.2A	ELEVATOR LOBBY	MECHANICAL ROOM	6' - 0"	7' - 0"	AA		<By Category>	1 3/4"	<By Category>	1	HM			SSI2-G-E2			
2-104A	BUILDING SUPPORT	CORRIDOR	6' - 0"	7' - 0"	AA		<By Category>	1 3/4"	<By Category>	1	HM			SSI2-G-E1			
2-104B	MECHANICAL ROOM		3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			E1-XO 3			
2-104UUUUUUUUUJJ	DATA HALL-10	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-104KKKKKKKKKKKKK	DATA HALL-10	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-106A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-107A	STORAGE	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-G-E3	90		
2-108A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-108B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-109A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-109B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-110A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-110B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-111A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-111B	ELEC. ROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-X O1			
2-112A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-113A	CORRIDOR	VALVE ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-114A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-115A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-115B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-116A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-116B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-117A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-117B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-118A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-119A	CORRIDOR	VALVE ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-120A	RESTROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-B3			
2-121A	CORRIDOR	RESTROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-B3			
2-122A	IDF	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-G-E1			
2-123A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-123B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-124A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-124B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-125A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-125B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-126A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-126B	ELEC. ROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-X O1			
2-127A	CORRIDOR	STORAGE	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-127B	STORAGE	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM						
2-128A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-129A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-130A	CORRIDOR	STORAGE	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-130B	STORAGE	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-G-E1			
2-131A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-131B	ELEC. ROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-X O1			
2-132A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-132B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-133A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-133B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-134A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-134B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-135A	CORRIDOR	RESTROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-B3			
2-136A	RESTROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-B3			
2-137A	CORRIDOR	STORAGE	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-138A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-139A	CORRIDOR	VALVE ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-140A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-140B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-141A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-141B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-142A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-142B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-143A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-144A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	60		
2-145A	VALVE ROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3			
2-146A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-146B	ELEC. ROOM	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-X O1			
2-147A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-147B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-148A	CORRIDOR	ELEC. ROOM	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XL1	90		
2-148B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-149A	ELEC. ROOM	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-149B	ELEC. ROOM	ELEC. ROOM	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-150A	STORAGE	CORRIDOR	9' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-G-E3	90		
2-150B	ELEC. ROOM	STORAGE	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-F-G-XL1			
2-151A	CORRIDOR	IDF	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SI1-E3	2		
2-152A	CORRIDOR	MECHANICAL	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-152B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-153A	CORRIDOR	DATA HALL-7	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		

DOOR SCHEDULE - LEVEL 2

DOOR NUMBER	ROOM		DOOR							FRAME		FRAME DETAILS					
	FROM ROOM	TO ROOM	WIDTH	HEIGHT	PANEL TYPE	MATERIAL	FINISH	THICKNESS	DOOR GLAZING	FRAME TYPE	MATERIAL	HEAD	JAMB	HARDWARE SET	FIRE RATING	STC RATING	COMMENTS
2-153B	DATA HALL-7	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-153C	DATA HALL-7	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-153D	DATA HALL-7	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-154A	DATA HALL-7	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-154B	DATA HALL-7	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-155A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-155B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-156A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-156B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-157A	DATA HALL-10	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-157B	DATA HALL-10	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-157C	DATA HALL-10	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-157D	DATA HALL-10	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-159A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-159B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-160A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-160B	CORRIDOR	MECHANICAL	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-161A	CORRIDOR	DATA HALL-8	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-161B	DATA HALL-8	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-161C	DATA HALL-8	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-161D	CORRIDOR	DATA HALL-8	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-162A	DATA HALL-8	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-162B	DATA HALL-8	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-163A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-163B	CORRIDOR	MECHANICAL	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-164A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-164B	CORRIDOR	MECHANICAL	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-165A	DATA HALL-11	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-165B	CORRIDOR	DATA HALL-11	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-165C	DATA HALL-11	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-165D	CORRIDOR	DATA HALL-11	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-166A	DATA HALL-11	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-166B	DATA HALL-11	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-167A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-167B	CORRIDOR	MECHANICAL	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-168A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-168B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-169A	CORRIDOR	DATA HALL-9	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-169B	DATA HALL-9	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-169C	DATA HALL-9	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-169D	DATA HALL-9	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-170A	DATA HALL-9	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-170B	DATA HALL-9	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-171A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-171B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-172A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-172B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-173A	DATA HALL-12	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-173B	DATA HALL-12	CORRIDOR	4' - 0"	9' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-G-XL1	90		
2-173C	DATA HALL-12	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-173D	DATA HALL-12	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-174A	DATA HALL-12	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-174B	DATA HALL-12	MISSION CRITICAL STORAGE	6' - 0"	10' - 0"	AA		<By Category>	1 3/4"	<By Category>	1				SSI2-E 3	90		
2-175A	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-175B	MECHANICAL	CORRIDOR	8' - 0"	10' - 0"	AA	HM	<By Category>	1 3/4"	<By Category>	1	HM			SSI2-F-G-XM 3	90		
2-225A	RR CORRIDOR	WOMEN'S RR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			I1-T3			
2-S01A	CORRIDOR	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S02A	STAIR	CORRIDOR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S03A	CORRIDOR	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S03B	ELEC. ROOM	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S04A	CORRIDOR	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S06A	CORRIDOR	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S07A	CORRIDOR	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			
2-S08A	CORRIDOR	STAIR	3' - 0"	7' - 0"	A		<By Category>	1 3/4"	<By Category>	1	HM			SSI1-F-XL2			

GENERAL DOOR NOTES

1. ALL WORK SHALL CONFORM TO ALL APPLICABLE CODES, ORDINANCES, AND STATUTES.
2. THE "DOOR NUMBER" INDICATES THE SCHEDULE DOOR-FRAME ASSEMBLY REFERENCED BY THE DOOR TAG INDICATED ON THE FLOOR PLANS. REFER TO THE "MATERIAL LEGEND", "FINISH LEGEND" AND FOR THE DESCRIPTION OF CORRESPONDING SYMBOLS FOR DOORS AND FRAMES AS SCHEDULED.
4. FRAME ASSEMBLIES SHALL COMPLY WITH "HEAD-JAM-MULLION-SILL" DETAILS AS SCHEDULED.
5. FIRE RATING REFERENCES FIRE RATING MINUTES FOR EACH ASSEMBLY, AS INDICATED BY THE "FIRE RATING LEGEND".
6. HARDWARE GROUP NUMBER REFERENCES DOOR-FRAME ASSEMBLY HARDWARE REQUIREMENTS AS SPECIFIED PER SPEC SECTION 08_71_00.
7. REFER TO DOOR COMMENTS FOR DOOR FRAME ASSEMBLY REQUIREMENTS INDICATED BY COMMENTS AS SCHEDULED.
8. FOR DOOR HARDWARE REFER TO SPECIFICATIONS.
9. FOR GLASS TYPES, REFER TO SPECIFICATIONS.
10. FOR PAINT SYSTEM REFER TO SPECIFICATIONS.
11. FOR PAINT COLORS, REFER TO FINISH LEGEND.
12. ALL DOOR AND FRAME COLORS TO MATCH UNLESS NOTED OTHERWISE.
13. REFER TO SECURITY DRAWINGS FOR DOOR ACCESS DEVICES.
14. KICK PLATES, AS SPECIFIED, SHALL BE 10"H MIN. & 2" LESS THAN DOOR WIDTH EITHER SIDE. ALL DOOR BOTTOM RAILS TO PROVIDE 10" H. MIN. SMOOTH SURFACE PER ADA REQUIREMENTS
15. REFER TO SPECIFICATIONS FOR TEMPORARY AND PERMANENT DOOR CORES.
16. PROVIDE PANIC HARDWARE AT ALL PHASE ONE AND FULL BUILD ELECTRICAL ROOM DOORS.

MATERIAL LEGEND

AL	ALUMINIUM	HM	HOLLOW METAL
GL	GLAZING	STL	STEEL
WD	WOOD		

FINISH LEGEND

ANOD.ALUM	ANODIZED ALUMINIUM
PAINT	PAINT AS SCHEDULED
STAIN	STAIN AS SCHEDULED

FIRE RATING LEGEND

-	NO RATING
45	45 MINUTE RATED DOOR, GLASS, AND FRAME ASSEMBLY AS SCHEDULED
90	90 MINUTE RATED DOOR, GLASS, AND FRAME ASSEMBLY AS SCHEDULED

GLAZING SCHEDULE

CODE	DESCRIPTION
GL- 1	INSULATED COATED GLASS UNIT WITH LOW-E COATING
GL- 6	FIRE-RATED GLASS

DOOR COMMENTS AS APPLICABLE

1. DOOR SWING 180 DEGREES.
2. ADD SIGN TO READ "FIRE RISER ROOM" ON OUTSIDE TO MEET THE REQUIREMENTS OF THE FIRE MARSHALL.
3. PROVIDE DOORBELL AT LATCH SIDE OF FRAME AT THIS LOCATION.
4. PROVIDE KNOX BOX ADJACENT TO THIS DOOR: COORDINATE LOCATION WITH FIRE MARSHALL.
5. EXTERIOR SIGNS TO BE CAST ALUMINUM.
6. SIDELITE ON BOTH SIDES OF DOOR 2'-1" W X 7'-0" H (REF FLOOR PLAN)
7. SIDELITE ON ONLY ONE SIDE OF DOOR 2'-1" W X 7'-0" H (REF FLOOR PLAN)
8. SIDELITES 6'-6 1/2" W X 7'-0" H (REF FLOOR PLAN)

serverfarm

CORGAN

TGRWA STRUCTURAL ENG