

- GENERAL NOTES - PIPING**
1. FOR SYMBOLS AND ABBREVIATIONS SEE DRAWING M03-00.
 2. FOR PROJECT DESIGN CRITERIA SEE DRAWING M03-01.
 3. PROVIDE LEAK DETECTION CABLE AROUND CRAH UNITS AND FAN WALLS.
 4. VALVE INDICATORS SHALL BE INSTALLED IN SUCH A MANNER AS TO ALLOW UNOBSTRUCTED OBSERVATION FROM MAINTENANCE AREA.
 5. ALL ESS INSTALLED WITHIN DATA HALL SPACES SHALL CONTAIN LESS THAN 20 kWh OF LITHIUM-ION ENERGY STORAGE PER SYSTEM TO COMPLY WITH 2023 NFPA 99.

KEYNOTE LEGEND

ISSUES

2	12.12.2025	SCHEMATIC DESIGN
4	1.23.2026	DESIGN DEVELOPMENT

REVISIONS

kW Mission Critical Engineering
 Contact: K. DREWNOWSKI Phone: 601.451.2099
 Engineer: K. COOPER License #: 23615 Exp. Date: 00/00/0000

NOT FOR CONSTRUCTION
 Date: 12/12/2025

SERVERFARM
 Clarksville, AR



LEVEL 1 - MECHANICAL PIPING PLAN - SEGMENT F

JOB US0049903.5614
SHEET

M03-01F

