WATER SOURCE HEAT PUMP SCHEDULE

	SUPPLY FAN		COOLING MODE								HEATING MODE									ELECTRICAL DATA							
EQUIPMENT TAG	SUPPLY CFM	ESP	NET SENSIBLE CAPACITY (MBH)	NET TOTAL CAPACITY (MBH)	EAT DB (°F)	EAT WB (°F)	LAT DB (°F)	LAT WB (°F)	EWT (°F)	LWT (°F)	HEATING CAPACITY (MBH)	EAT DB (°F)	LAT DB (°F)	EWT (°F)	LWT (°F)	FLOW (GPM)	EER	COP	REFRIGERANT TYPE	VOLTAGE	PHASE	MCA	MOCP	DIMENSIONS	MANUFACTURER	MODEL	NOTES
WSHP-1-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-1-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-1-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-2-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-2-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-2-3	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-2-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-3-1	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-3-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-3-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-3-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-3-5	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-3-6	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-4-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-4-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-4-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-5-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-5-2	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-5-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-5-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-6-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-6-2	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-6-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-6-4	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-6-5	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-6-6	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-7-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-7-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-7-3	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-7-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-8-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-8-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-8-3	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-8-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-9-1	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-9-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-9-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-9-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-9-5	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-9-6	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-10-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-10-2	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-10-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-10-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-11-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-11-2	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-11-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-11-4	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-12-1	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-12-2	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-12-3	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-12-4	520	0.6	14.6	15.1	80	63	53.8	52.8	66 °F	81.6 °F	18.2	68	100.6	66 °F	53.5 °F	2.4	18.2	4.75	R-454B	265	1	10	15	46L X 26W X 18H	TRANE	GEHK015	
WSHP-12-5	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	
WSHP-12-6	1200	0.6	35.0	38.6	80	63	52.9	51.6	66 °F	82.3 °F	42.8	68	101.1	66 °F	54.5 °F	5.9	18.2	4.75	R-454B	265	1	10	15	55L X 26W X 20H	TRANE	GHEK0.36	

NOTES:
1. SEE FLOOR PLANS FOR HANDEDNESS OF RETURN AIR INLET. UNITS TO BE CONFIGURED WITH SIDE INLET AND END DISCHARGE.
2. PROVIDE UNIT WITH BACNET COMPATIBLE CONTROLLER AND FACTORY PROVIDED/INSTALLED TWO-WAY CONTROL VALVE.
3. UNIT TO BE SUSPENDED FROM STRUCTURE.

ROOFTOP UNIT SCHEDULE

			SUPPLY FAN					EXHAUST FAN						COOLING COIL							ELECTRIC HEATING COIL					ELECTRICAL DATA											
EQUIPMENT TAG	SUPPLY CFM	OA CFM	QTY	ESP	RPM	BHP / FAN	HP / FAN	EXHAUST CFM	QTY	ESP	RPM	BHP / FAN	HP / FAN	NET SENSIBLE CAPACITY (MBH)	NET TOTAL CAPACITY (MBH)	COIL EAT DB (°F)	COIL EAT WB (°F)	COIL LAT DB (°F)	COIL LAT WB (°F)	COIL EER	HEATING CAPACITY (KW)	HEATING AIRLFOW (CFM)	COIL EAT DB (°F)	COIL LAT DB (°F)	DESIGN SUPPLY LAT DB (°F)	REFRIGERANT TYPE	V	PH	HZ	FLA	MCA	MOCP	DIMENSIONS (LxWxH)(IN)	WEIGHT (LBS)	MANUFACTURER	MODEL	NOTES
RTU-R-1	9500	2200	2	1.5	2052	3.2	5.0	9000	1	0.5	1563	3.2	8	276.79	438.58	81	68	52	52	11.0	60	4000	36.1	83.5	55 °F	R-454B	460	3	60	113.4	115	125	340 x 91 x 82	9100	TRANE IPAK	RE 040 BB43	
RTU-R-2	15000	3500	2	2.0	1804	7.4	7.5	14000	2	0.5	1233	3.4	8	408.56	643.89	81	68	53	53	10.6	90	6000	34.2	81.6	55 °F	R-454B	460	3	60	164.6	166	175	340 x 116 x 82	11200	TRANE IPAK	RE 060 CB43	
RTU-R-3	1500	400	1	1.0	923	0.5	3.0	1350	1	-	-	-	-	37.09	57.47	82	69	55	55	12.2	18	900	42.2	105.4	90 °F	R-454B	460	3	60	26.2	35	35	7.4 x 4.4 x 4.3	1000	TRANE PRECEDENT	THK 060 A450G	

NOTES:
1. PROVIDE UNIT WITH 24" ROOF CURB.
2. PROVIDE UNIT WITH FACTORY INSTALLED SMOKE DETECTOR, PRE-WIRED TO UNIT CONTROLLER FOR SHUT DOWN.
3. UNIT TO BE PROVIDED TO FACTORY CONTROLLER. SEE 23 09 93 FOR SEQUENCE OF OPERATION.

FAN POWERED TERMINAL UNIT SCHEDULE (ELECTRIC HEAT)

			PRIMARY CFM			FAN DATA				ELECTRIC HEATING COIL						ELECTRICAL		NC LEVELS				
EQUIPMENT TAG	RTU	UNIT SIZE	MAX	MIN	HEATING	CFM	ESP	HP	CFM	KW	EAT DB	LAT DB	VOLTAGE	PHASE	FREQUENCY	MCA	MOCP	RADIATED	DISCHARGE	MANUFACTURER	MODEL	NOTES
FPB-R1-01	RTU-R-1	02 08	700	210	210	390	0.25	0.17	600	5.5	63.5	92.4	480	3	60	9.9	15	36	28	TITUS	DTQP	
FPB-R1-02	RTU-R-1	02 08	500	150	150	250	0.25	0.17	400	3.5	63.1	90.8	480	3	60	6.9	15	32	24	TITUS	DTQP	
FPB-R1-03	RTU-R-1	04 12	1800	540	540	860	0.25	0.33	1400	12.0	63.0	90.1	480	3	60	21.7	25	38	27	TITUS	DTQP	
FPB-R1-04	RTU-R-1	02 08	600	180	180	300	0.25	0.17	480	4.5	63.1	92.8	480	3	60	8.4	15	34	25	TITUS	DTQP	
FPB-R1-05	RTU-R-1	05 14	2000	600	600	1400	0.25	0.33	2000	17.0	64.1	91.0	480	3	60	29.6	30	42	28	TITUS	DTQP	
FPB-R1-06	RTU-R-1	02 08	750	230	230	370	0.25	0.17	600	5.5	63.0	92.0	480	3	60	9.9	15	36	25	TITUS	DTQP	
FPB-R2-01	RTU-R-2	02 08	750	230	230	370	0.25	0.17	600	5.5	63.0	92.0	480	3	60	9.9	15	36	25	TITUS	DTQP	
FPB-R2-02	RTU-R-2	05 14	2400	720	720	1280	0.25	0.33	2000	17.0	63.3	90.2	480	3	60	29.6	30	42	27	TITUS	DTQP	
FPB-R2-03	RTU-R-2	02 10	850	250	250	400	0.25	0.17	650	5.0	63.0	87.3	480	3	60	9.1	15	36	27	TITUS	DTQP	
FPB-R2-04	RTU-R-2	02 08	600	180	180	300	0.25	0.17	480	4.5	63.1	92.8	480	3	60	8.4	15	34	25	TITUS	DTQP	
FPB-R2-05	RTU-R-2	02 10	800	240	240	460	0.25	0.17	700	6.0	63.5	90.6	480	3	60	10.6	15	38	28	TITUS	DTQP	
FPB-R2-06	RTU-R-2	03 08	700	210	210	490	0.25	0.25	700	6.0	64.1	91.2	480	3	60	11.8	15	36	23	TITUS	DTQP	
FPB-R2-07	RTU-R-2	02 08	600	180	180	300	0.25	0.17	480	4.5	63.1	92.8	480	3	60	8.4	15	34	25	TITUS	DTQP	
FPB-R2-08	RTU-R-2	03 10	1200	360	360	540	0.25	0.25	900	8.0	62.8	90.9	480	3	60	14.8	15	29	27	TITUS	DTQP	
FPB-R2-09	RTU-R-2	05 14	2500	750	750	1250	0.25	0.33	2000	17.0	63.1	90.0	480	3	60	29.6	30	41	27	TITUS	DTQP	

NOTES:
1. PROVIDE FAN POWERED TERMINAL UNIT WITH AN SCR CONTROLLED ELECTRIC RESISTANCE REHEATING COIL.
2. DIV. 23 CONTROLS CONTRACTOR TO PROVIDE FPB CONTROLLER.

VAV BOX SCHEDULE (ELECTRIC HEAT)

						CFM		ELECTRIC HEATING COIL							ELECTRICAL		NC LEVEL				
EQUIPMENT TAG	PHASE	RTU	LOCATION	SERVICE	UNIT SIZE	MAX	MIN	CFM	KW	EAT DB	LAT DB	VOLTAGE	PHASE	FREQUENCY	MCA	MOP	RADIATED	DISCHARGE	MANUFACTURER	MODEL	NOTES
VAV-R1-01	PHASE 1	RTU-R-1			08	500	150	250	2.5	55	86.6	480	3	60	3.8	15	20	27	TITUS	DESV	
VAV-R1-02	PHASE 1	RTU-R-1			06	400	120	250	2.5	55	86.6	480	3	60	3.8	15	24	25	TITUS	DESV	
VAV-R1-03	PHASE 1	RTU-R-1			08	550	170	280	3.0	55	88.9	480	3	60	4.5	15	22	27	TITUS	DESV	
VAV-R1-04	PHASE 1	RTU-R-1			06	400	120	250	2.5	55	86.6	480	3	60	3.5	15	24	25	TITUS	DESV	
VAV-R1-05	PHASE 1	RTU-R-1			14	1800	540	1000	10.0	55	86.6	480	3	60	15.0	15	22	20	TITUS	DESV	
VAV-R2-01	PHASE 1	RTU-R-2			06	400	120	250	2.5	55	86.6	480	3	60	3.8	15	24	25	TITUS	DESV	
VAV-R2-02	PHASE 1	RTU-R-2			06	300	100	150	1.5	55	86.6	208	3	60	5.2	15	20	22	TITUS	DESV	
VAV-R2-03	PHASE 1	RTU-R-2			08	700	210	350	3.5	55	86.6	480	3	60	5.3	15	24	29	TITUS	DESV	
VAV-R2-04	PHASE 1	RTU-R-2			08	700	210	350	3.5	55	86.6	480	3	60	5.3	15	24	29	TITUS	DESV	
VAV-R2-05	PHASE 1	RTU-R-2			10	1100	300	600	6.0	55	86.6	480	3	60	9.0	15	24	28	TITUS	DESV	
VAV-R2-06	PHASE 1	RTU-R-2			10	1000	300	600	6.0	55	86.6	480	3	60	9.0	15	24	27	TITUS	DESV	
VAV-R2-07	PHASE 1	RTU-R-2			08	550	170	280	3.0	55	88.9	480	3	60	4.5	15	22	27	TITUS	DESV	
VAV-R2-08	PHASE 1	RTU-R-2			06	400	120	250	2.5	55	86.6	480	3	60	3.8	15	24	25	TITUS	DESV	

NOTES:
1. PROVIDE FAN POWERED TERMINAL UNIT WITH AN SCR CONTROLLED ELECTRIC RESISTANCE REHEATING COIL.
2. DIV. 23 CONTROLS CONTRACTOR TO PROVIDE FPB CONTROLLER.

SPLIT-SYSTEM INDOOR UNIT SCHEDULE

					COOLING INFORMATION			HEATING INFORMATION				ELECTRICAL DATA										
EQUIPMENT TAG	PHASE	LOCATION	ASSOCIATED OUTDOOR UNIT	UNIT TYPE	TOTAL COOLING CAPACITY (BTU/HR)	EAT DB (°F)	EAT WB (°F)	TOTAL HEATING CAPACITY (BTU/HR)	EAT DB (°F)	REFRIGERANT TYPE	SUPPLY FAN (CFM)	VOLTAGE	PHASE	FREQUENCY	DISCONNECT	MCA	MOCP	WEIGHT (LBS)	DIMENSIONS (HxWxD)(IN)	MANUFACTURER	MODEL	NOTES
AC-1-01	PHASE 1	ELECTRICAL 1-108A	ACCU-R-1	WALL-MOUNTED UNIT	24000	80	67		-	R-32	754	208	1	60	BY EC	-	-	35	12 x 40 x 11	DAIKIN	FTKF 24 AXVJU	
AC-1-02	PHASE 1	ELECTRICAL 1-141	ACCU-R-2	WALL-MOUNTED UNIT	24000	80	67		-	R-32	754	208	1	60	BY EC	-	-	35	12 x 40 x 11	DAIKIN	FTKF 24 AXVJU	
AC-2-01	PHASE 1	ELECTRICAL 1-104.1	ACCU-R-3	WALL-MOUNTED UNIT	24000	80	67		-	R-32	754	208	1	60	BY EC	-	-	35	12 x 40 x 11	DAIKIN	FTKF 24 AXVJU	

NOTES:
1. INDOOR UNIT POWERED BY OUTDOOR UNIT. SEE INSTALLATION MANUAL FOR DETAILS. ALL WIRING FOR POWER AND CONTROLS SHOULD BE IN CONDUIT.
2. INDOOR UNIT MOUNTED TO WALL.
3. PROVIDE CONDENSATE LIFT KIT ACCESSORY. RUN CONDENSATE TO NEAREST FLOOR DRAIN OR AS INDICATED.

SPLIT-SYSTEM OUTDOOR AIR COOLED CONDENSING UNIT SCHEDULE

			COOLING DATA			HEATING DATA			REFRIGERANT		ELECTRICAL DATA									
EQUIPMENT TAG	PHASE	AMBIENT TEMP (F)	RATED COOLING CAPACITY (BTU/HR)	EER	IEER / SEER	RATED HEATING CAPACITY (BTU/HR)	COP 47	COP 17	TYPE	QTY (LBS)	VOLTAGE	PHASE	FREQUENCY	RLA / FLA	MCA	MOCP	WEIGHT (LBS)	MANUFACTURER	MODEL	N