

4 FIRE ALARM ENLARGED PLANS - VALVE ROOM 2-139
1/4" = 1'-0"



5 FIRE ALARM ENLARGED PLANS - VALVE ROOM 2-145
1/4" = 1'-0"



3 FIRE ALARM ENLARGED PLANS - VALVE ROOM 2-119
1/4" = 1'-0"



2 FIRE ALARM ENLARGED PLANS - VALVE ROOM 2-113
1/4" = 1'-0"



1 FIRE ALARM ENLARGED PLANS - STORAGE 2-107
1/4" = 1'-0"

DEFERRED SUBMITTAL
ALL WORK SHOWN IS
TO ILLUSTRATE
DESIGN INTENT

serverfarm
CORGAN
TGRWA
STRUCTURAL ENGINEERS
kW Mission Critical Engineering
Member of WSP
EP ENGINEERING PLUS
Kimley»Horn

ISSUES

3	01.23.2026	60% DESIGN DELIVERABLE

REVISIONS

kW Mission Critical Engineering
Contact: Stephan Slabicky Phone: 212.951.3943
Engineer: EOR
License #: 123456 Exp. Date: 00/00/0000

NOT FOR CONSTRUCTION

Date: 00/00/0000

SERVERFARM

Clarksville, AR

ENLARGED FIRE ALARM PLANS

JOB US0049903.5614
SHEET

FA03-02

1/23/2026 4:02:35 PM FA03-02 ENLARGED FIRE ALARM PLANS