

1. REFER TO SPECIFICATION 29.09.00 FOR CONTROLS RELATED INSTALLATION REQUIREMENTS.
2. REFER TO SPECIFICATION 29.09.93 FOR SEQUENCE OF OPERATIONS.
3. REFER TO ELECTRICAL PROJECT SPECIFICATIONS FOR ALL WIRING INSTALLATION REQUIREMENTS.
4. INSTALL FLEXIBLE CONNECTIONS IN RUNS OF RACEWAYS, CABLES, WIREWAYS, CABLE TRAYS, AND WIREWAYS. FLEXIBLE CONNECTIONS SHALL BE USED AT SEISMIC JOINTS, OR ARE SUBJECT TO STRUCTURAL ENGINEER'S INTERPRETATION. BUILDING DEPT. FLEXIBLE CONNECTIONS SHALL BE INSTALLED WHERE ANCHORED, ADJUSTABLE CONNECTIONS OF RACEWAYS ARE SUPPORTED BY DIFFERENT STRUCTURAL ELEMENTS. FLEXIBLE CONNECTIONS SHALL BE USED TO EQUIPMENT THAT IS ANCHORED TO DIFFERENT STRUCTURAL ELEMENTS. CONTRACTOR SHALL COORDINATE WITH ARCHITECT AND/OR ARCHITECTURAL ENGINEER IN ORDER TO PROVIDE THE REQUIRED FLEXIBLE CONNECTIONS.
5. CONTRACTOR SHALL COORDINATE INSTALLATION WITH ALL OTHER CONTRACTORS AND OTHER TRADES AS NEEDED. THIS INCLUDES COORDINATING EQUIPMENT LOCATION AND INSTALLATION WITH OWNER REPT TO INCORPORATE ANY TENANT REQUIREMENTS FOR SENSORS.
6. INSTALLATION OF ALL THERMOSTATS AND DIFFERENTIAL TEMPERATURE SENSORS SHALL BE COORDINATED WITH ALL OTHER WALL DEVICES FOR INSTALLATION HEIGHT ABOVE FINISHED FLOOR.
7. CONTROL PANELS ARE DERIVED FROM TWO SEPARATE 120VAC POWER SOURCES.
8. PROVIDE FIELD COORDINATION WITH SYSTEM INTEGRATOR ON ALL PANELS.
9. CONTROLS AND ELECTRICAL CONTRACTORS TO COORDINATE ALL ETHERNET CPOWERS AND FIBER OPTIC AND TELECOM CABLES.

[illegible]

1	01.23.2026	DESIGN DEVELOPMENT
---	------------	--------------------

--	--	--

Contact: Alex Tate Phone: 404.829.8031
Engineer:
License #: Exp. Date:

NOT FOR CONSTRUCTION

Date: 01/23/2026

SF - ARK01
DESIGN DEVELOPMENT

CLARKSVILLE, AR 72830

L	K	J	
G	E	C	A
H	F	D	B
P	N	M	

LEVEL 1 -
CONTROLS PLAN -
SEGMENT P

JOB US0049903.5614
SHEET

IC02-01P

① LEVEL 1 - CONTROLS PLAN - SEGMENT P
1/8" = 1'-0"