

T05-07

GENERAL NOTES

EC SHALL PROVIDE (1) TELECOMMUNICATIONS GRONDING BUSBAR (TGB) AND (1) ELECTRICAL GROND BUS BAR (EGB) IN EACH MIRROR. BOND THE TGB TO THE EGB WITHIN THE SAME ROOM USING A LISTED CLIMPER. EACH ROOM'S EGB SYSTEM SHALL BE BOND TO THE BUILDING GRONDING SYSTEM (GCS) UNDER DIVISION 26 ELECTRICAL. SEE INSTALLATION, BONDING, AND LABELING SHALL COMPLY WITH ITA-607 AND NEC ARTICLE 250. SEE T01.01 GENERAL REQUIREMENTS SECTION 6.2.2 AND T02.20 ADDITIONAL COMMUNICATION REQUIREMENTS FOR FURTHER GRONDING REQUIREMENTS. SEE ELECTRICAL DRAWINGS FOR DETAILS, WHERE REQUIREMENTS CONFLICT, THE ELECTRICAL DRAWINGS SHALL GOVERN. FINAL TERMINATION, CONTINUITY, AND TESTING BY ELECTRICAL CONTRACTOR.