

SECTION 01 41 00
REGULATORY REQUIREMENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Regulatory requirements.

1.2 REGULATORY REQUIREMENTS

- A. Additional information with legal implications regarding applicable governing laws and jurisdictions can be found in Conditions of Contract.
- B. Codes:
 - 1. Where references are made on Drawings or Specifications to codes, they shall be considered an integral part of the Contract Documents as minimum standards. Nothing contained in Contract Documents shall be so construed as to be in conflict with law, bylaw or regulation of municipal, State, Federal, or other authorities having jurisdiction.
 - 2. Perform Work in compliance with the Building and other Codes listed on Drawings as adopted by the City of Clarksville, AR.
 - 3. Perform work in compliance with:
 - a. National, state and local barrier free codes, laws and ordinances.
 - b. Local Adopted Elevator Code.
 - c. NFPA 101 - Life Safety Code and other applicable NFPA Standards.
- C. Without additional expense to Owner, obtain necessary licenses and permits, and be responsible for complying with Federal, state, county, and municipal laws, codes, and regulations applicable to performance of Work, including, but not limited to, laws or regulations requiring use of licensed contractors to perform parts of work.
- D. Environmental Requirements: Comply with applicable local, state, and federal air and water quality standards with pollution control laws; and with rules, regulations and directives lawfully issued for the protection of the environment in the areas surrounding the confines of this contract.
- E. Occupancy Permit: Secure the Certificate of Occupancy Permit at completion of Project and deliver fully executed Permit to Owner. Final Payment shall be retained until Permit has been received by Owner.

1.3 FIRE RESISTANCE REQUIREMENTS

- A. Fire Resistance Ratings and Fire Tests: Fire resistance ratings of building elements, components, and assemblies shall be determined only in accordance with the test

procedures set forth in ASTM E 119 or UL 263, or by alternative methods approved by applicable authorities having jurisdiction.

1. Fire resistance ratings shall be determined or listed based on fire tests performed by one of the following testing agencies, or other agencies acceptable to governing authorities having jurisdiction.
 - a. Factory Mutual Laboratories.
 - b. Intertek
 - c. Southwest Research Institute.
 - d. Underwriters Laboratories, Inc.
 2. Where reference is made to only one testing authority, equivalent fire ratings as determined or listed by another testing agency are acceptable if approved by applicable Authorities Having Jurisdiction.
- B. Marking and Identification: Fire walls, fire barriers, fire partitions, smoke barriers, and smoke partitions, or any other walls required to have protected openings or penetrations, shall be permanently identified with signage or stenciling. Such identification shall:
1. Be located in accessible floor plenums, ceiling plenums, or attic spaces.
 2. Be repeated at intervals not exceeding 30 feet o.c., measured horizontally along the partition or wall.
 3. Include lettering not less than 0.5 inch (15 mm) in height, worded as follows: "FIRE AND/OR SMOKE BARRIER – PROTECT OPENINGS AND PENETRATIONS."
 - a. Where individual Sections require larger lettering, comply with the larger requirement.

PART 2 - PRODUCTS
Not used.

PART 3 - EXECUTION
Not used.

END OF SECTION